


<b><u>FIRE FLOW CALCULATION ACCEPTANCE</u></b>	<b><u>WATER /SEWER LEVEL OF SERVICE ANALYSIS</u></b>
<u>Address of project:</u> <b>511 W. Maitland Blvd.</b> <b>Maitland, FL 32751</b>	<u>Address of project:</u> <b>511 W. Maitland Blvd.</b> <b>Maitland, FL 32751</b>
Required Fire Flow per City: <u>1,000</u> gpm	water gpd: <u>261,450*</u> *both at ultimate
Fire Flow available for Project per Engineered Calculations: <u>1,000 / 2,000*</u> gpm	sewer gpd: <u>224,100*</u> buildout per PD entitlements
Accepted by: _____ <small>*varies by building, see hydraulic analysis and utility plans</small>	 Engineer's Signature
 Fire Marshal or Designee	<u>6/20/16</u> Date
<u>Copy of Sealed Calculations attached</u>	NOTE: Attach demand calculations signed and sealed by Engineer of Record.

**CERTIFICATION**

I do hereby certify that I, the undersigned, have read the above information and have full understanding to the best of my knowledge and belief that all information supplied with this application is true and accurate.

Signature  Date 6/27/2016

Owner  Applicant

Print Name Maximo Cruz